



**IZOL PLAST**

Sp. z o.o.  
44-362 Rogów  
ul. Raciborska 79  
tel./fax 32-4512444,  
32-4512010  
[www.izol-plast.rogow.pl](http://www.izol-plast.rogow.pl)

ISO 9001  
OBAC/002/SZJ/20

## INDEX CARD

### Undervoltage release switching off ZCT-1 (NW1 / 07-100)

#### Application:

ZCT-1 (NW1 / 07-100) undervoltage release is used in ROK-6 distribution bays to break the circuit.



#### Data:

Rated voltage:	100V
Rated frequency:	50Hz
Windings:	Ø0,35 zw. 750 Ø0,05 zw. 40000