
 <p>ISO 9001 OBAC/002/SZJ/20</p>	<p><b>P.H.P.U.</b>  <b>IZOL PLAST</b> </p> <p>Sp. z o.o.  44-362 Rogów  ul. Raciborska 79  tel./fax 32-4512444,  32-4512010  <a href="http://www.izol-plast.rogow.pl">www.izol-plast.rogow.pl</a></p>	<p><b>INDEX CARD</b></p>
		<p><b>Plate for fastening GN bushings of the transformer compartment</b></p>

**The GN side isolators mounting plate** is used for mounting PTH 3-6 / 200 type bushings or resin bushings with ATEX marking, APTH 3-6 / 200 type. Mounting bolts M10 are used for the assembly of insulators and complete sheet metal in the transformer chamber. The plate fixing the insulators of the GN side is installed in the transformer chamber in the flameproof transformer stations type IT3S ... and the series of types of flameproof transformer stations type MAR -.....

