



ISO 9001  
OBAC/002/SZJ/23

P.H.P.U.  
**IZOL PLAST**

Sp. z o.o.


44-362 Rogów  
ul. Raciborska 79  
tel./fax 32-4512444,  
32-4512010  
[www.izol-plast.rogow.pl](http://www.izol-plast.rogow.pl)

## INDEX CARD

### Fire absorber cap Z-UPO type

#### Application:

The Z-UPO fire absorber plug is intended for use in flameproof transformers and ROK .. switchboards. The plugs are the accessories that enable to plug the fire absorber sockets.



#### Certificate:

The Z-UPO fire absorber cap has the EU type examination certificate: **KDB 07ATEX102U / 2** of **23.05.2011**, carried out by the Central Mining Institute, the Certification Body of the Experimental Mine "Barbara" as a supplement to the EU-type examination certificate **KDB 07ATEX102U** of **February 28, 2007**, and meets the requirements of the following standards:

- PN-EN 60079-0:2013 (EN 60079-0:2012),
- PN-EN 60079-1:2014 (EN 60079-1:2014).

The Z-UPO type flame absorber plug was marked in accordance with the EU-type examination certificate as follows:



1461

**KDB 07ATEX102U**

**I M2 Ex d I Mb**