

 <p>ISO 9001 OBAC/002/SZJ/23</p>	<p><b>IZOL PLAST</b> P.H.P.U.</p> <p>Sp. z o.o. 44-362 Rogów ul. Raciborska 79 tel./fax 32-4512444, 32-4512010 <a href="http://www.izol-plast.rogow.pl">www.izol-plast.rogow.pl</a></p>	<p style="text-align: center;"><b>INDEX CARD</b></p> <p style="text-align: center;"><b>Plug of switching chamber's socket type ZGKP-ROK</b></p>
---	---	---

**Application:**

Plug of switching chamber's socket type ZGKP-ROK is intended for installation in the device when the OSzP-ROK busbar is not introduced into the device.

Zaślepka typu ZGKP-ROK wykonana jest jako konstrukcja spawana z elementów stalowych.

The plug is attached to the device with M16 screws. There is a flameproof cylindrical-flange joint between the flange and the flameproof enclosure of the device.

**Certificate:**

Plug of switching chamber's socket type ZGKP-ROK has the EU type examination certificate: **KDB 06ATEX237U / 3** of **18.07.2012**. made by the Central Mining Institute, the Certification Body of the Experimental Mine "Barbara" as a supplement to the EU-type examination certificate **KDB 06ATEX237U** of **September 25, 2006**.

The basic requirements of safety and health protection were implemented by meeting the requirements of the standards:

- PN-EN 60079-0:2013,
- PN-EN 60079-1:2014.

The plug of the socket of the ZGKP-ROK type switching chamber was marked in accordance with the EU-type examination certificate as follows:



**KDB 06ATEX237U**  
**I M2 Ex d I Mb**  
**1461**