



P.H.P.U.

Sp. z o.o.
44-362 Rogów
ul. Raciborska 79
tel./fax 32-4512444,
32-4512010
www.izol-plast.rogow.pl

ISO 9001
OBAC/002/SZJ/23

INDEX CARD

Bushing for the circuits of flameproof interlocks of transformer stations type IPS-4/250



Application:

The **IPS-4/250** type bushing is intended for the passage of blocking circuits in flameproof transformer stations manufactured by the "MEFTA" Mikołów factory.

Replaces PSA-4W / N and PSA-4W / Nz insulator

Construction of the IPS-4/250 insulator:

- ▲ the culvert is made of polyamide,
- ▲ the insulator has 4 brass pins,
- ▲ insulator ferrule made of quality steel,
- ▲ special and rectangular washers,
- ▲ fastening nuts.

Technical data of the IPS-4/250 insulator

Rated voltage U_N	250 [V]
Rated current I_N	5 [A]
Weight	0,350 [kg]
Dimensions	108 x 63[mm]
Nominal diameter of the clamps	M5
Maximum torque acting on the terminal [Nm]	3,2 [Nm]

Opinions, judgments:

Positive Attestation Opinion along with the KD "Barbara" Decision, number **L.dz.KD 4/7999/2001/201 / inż.DP**

Feature of explosion-proof construction: **ExdI KDB Nr 01.150X.**