

 <p>ISO 9001 OBAC/002/SZJ/23</p>	<p>P.H.P.U. IZOL PLAST Sp. z o.o. 44-362 Rogów ul. Raciborska 79 tel./fax 32-4512010 www.izol-plast.rogow.pl</p>	<p>INDEX CARD</p> <p>Disconnecter / isolator switch mechanism drive screw</p>
---	---	---

The drive screw of the disconnecter / isolator switch mechanism is used to switch on and off the disconnecter / isolator of the transformer station at the upper rated voltage.

Changing the position of the disconnecter / isolator Q1 contacts takes place after turning the screw shaft of the mechanism drive, as a result of which the disconnecter / isolator lever arrangement is changed.

