

 <p>OBAC CERTIFIED QMS PN-EN ISO 9001 ISO 9001 OBAC/002/SZJ/23</p>	<p>P.H.P.U. IZOL PLAST Sp. z o.o. 44-362 Rogów ul. Raciborska 79 tel./fax 32-4512444, 32-4512010 www.izol-plast.rogow.pl</p>	<p>INDEX CARD</p> <p>Locks' blockades for flameproof transformer stations IT3S and MAR</p>
---	---	--

The locks are used to close the flameproof transformer stations type IT3S ... and the series of types of flameproof transformer stations type MAR -.....

The set of locks consists of three locks and one key. The locks are available in several dozen key versions.

The set of locks is made in accordance with the technical documentation of flameproof transformer stations IT3Sb, IT3Sd, IT3Sc and IT3Sm, and the series of types of flameproof transformer stations type MAR -.....

The set of locks is made as a welded structure. The set of locks is protected against corrosion by galvanic coating with a layer of zinc.

